

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.1508

Dated: 29/05/2025


It is certified that an inspection team headed by SANJAY KUMAR (Name of Officers with designation) from J.En PHED DUNGARGARH.....

Inspected the AG MISSION SR. SEC. SCHOOL, DUNGARGARH.....

(Name & Address of the school) on 10/05/2025.(date of inspection) and on the basis of Water Test Report (Attached) bearing no114..... dated.....20/05/2025..... of.....DISTRICT LAB BIKANER.....(PHED Lab)certified that the

AG MISSION SR. SEC. SCHOOL, DUNGARGARH.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...28/05/2028.....


सहायक अभियंता
जन स्वा. अभि. विभाग
उप खंड डूंगरगढ़

Signature with Seal:
Name :
Designation :
Name & Address of the Office/Department:.....

To
AG MISSION SR. SEC. SCHOOL
DUNGARGARH.....
(Name & Address of the Institution)



Public Health Engineering Department
Office Of Senior Chemist
Bikaner



No. Lab/Tech(Chem)/2024-25/ 887

Dated : 20/5/25

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Rajneesh Kaushik (Principal)
AG MISSION SR. SEC. SCHOOL
DUNGARGARH, DIST. BIKANER

District: Bikaner
Block: Dungargarh

Reference : L C S Letter No.

Dated: 20-05-2025

Date of Receipt : 20-05-2025

Exam. Date: May-25

Date of Receipt : 20-05-2025

Exam Date : 20-05-2025

LS No.	BIS 10500; 2012 Drinking Water Standards	DL-Bhl / Rt/ 24-25/ 1524					
Panchyat							
Village/City		Dungargarh					
Habitation		Dungargarh					
Source	Maximum Desirable Limit	Maximum Permissible Limit	Ro AG Mission Sr. Sec. School				
Date of Collection			17-05-2025				
Name of Sample Taker			Naina Teacher				
Note : - All results except pH are in mg/L.							
1	pH	6.5-8.5	NR	7.41			
2	TDS	500	2000	449			
3	Turbidity	1	5	0			
4	Total Alkalinity (As CaCO3)	200	600	215			
5	Total Hardness (As CaCO3)	200	600	202			
6	Chloride	250	1000	121			
7	Sulphate	200	400	47			
8	Nitrate	45	NR	1.7			
9	Calcium Hardness	188	500	133			
10	Magnesium Hardness	125	417	69			
11	Fluoride	1	1.5	0.51			
12	Conductivity	-	-	670			
13	Sodium	-	-	32			
14	Potassium	-	-	3			

Samples Not Collected by Laboratory
Not for Legal Purposes

Senior Chemist
PHED District Laboratory
Bikaner
Dated :

No. Lab/Tech(Chem)/2024-25/
Copy to - Supt. Chemist Chemist PHED Lab, Ajmer

Senior Chemist
PHED District Laboratory
Bikaner

